















CEILING PLAN LEGEND		TOTAL FIXTURES
	EXIST. 2x4 PRISMATIC LIGHTING TO REMAIN	95
	EXIST. 2x4 PRISMATIC LIGHTING TO BE RELOCATED	21
	EXIST. 2x2 PRISMATIC LIGHTING TO REMAIN	5
	EXIST. 2x2 PRISMATIC LIGHTING TO BE RELOCATED	3
	NEW 1x3 WALL MOUNTED STRIP FIXTURE	1
	EXIST. EXIT SIGN TO REMAIN	3
	NEW EXIT SIGNS BY TENANT G.C.	1
	RELOCATED EXIT SIGNS	2
	EXIST. SPEAKER TO REMAIN	5
	NEW SPEAKER BY TENANT G.C.	2
	RELOCATED SPEAKER	2
	NEW EXHAUST FAN W/ THERMOSTAT CONTROL	1
	NEW WALL SWITCH	2
	RELOCATED WALL SWITCH	8

REFLECTED CEILING PLAN KEYED NOTES	
1	E.G. TO VERIFY PROPER OPERATION OF EMERGENCY AND GENERAL LIGHT FIXTURES PRIOR TO REMOVAL. RETAIN CIRCUIT CONTINUITY AND LOCAL AREA SWITCHING OF ALL LIGHTING CIRCUIT(S) REMOVED, UNLESS OTHERWISE NOTED. E.G. TO PROTECT REMOVED FIXTURES FOR REUSE.
2	E.G. TO VERIFY EXISTING WALL SWITCH HEIGHT AND HORIZONTAL DISTANCE FROM NEAREST WALL, DOORWAY, ETC. PRIOR TO REMOVAL. PROVIDE JUNCTION BOX AND EXTEND LOCAL LIGHTING CONTROL SWITCHES TO NEW LOCATION SHOWN AT HEIGHT AND HORIZONTAL DISTANCE AS REMOVED, VERIFY A.D.A. COMPLIANCE.
3	RELOCATED 277-VOLT, 4-LAMP, 2x4 FLUORESCENT FIXTURE TO NEW LOCATION SHOWN. PROVIDE JUNCTION BOX AND EXTEND EXISTING AREA CIRCUIT TO FIXTURE. CLEAN AND RELAMP FIXTURE. REPLACE BALLAST, ONLY AS NECESSARY.
4	E.G. TO PROVIDE A NEW WALL MOUNTED, 3'-0", 2-LAMP, STRIP FIXTURE ABOVE DOOR IN SERVER ROOM.
5	E.G. TO REMOVE EXISTING 2x2 LIGHT FIXTURE IN DATA CLOSET (RETAIN FOR FUTURE USE). PROVIDE JUNCTION BOX AND EXTEND "SWITCHED" CIRCUIT TO NEW WALL MOUNTED FIXTURE ABOVE DOOR.
6	CONNECT NEW EXHAUST FAN TO A LOCAL "UNSWITCHED" CIRCUIT. FAN SHALL BE THERMOSTATICALLY CONTROLLED. MAKE FINAL CONNECTIONS. VERIFY WITH MECHANICAL.
7	E.G. TO PROVIDE A NEW JUNCTION BOX AND WALL SWITCH FOR CONTROL OF LOCAL LIGHTING. INSTALL SWITCH PER A.D.A. REQUIREMENTS. IF NO EXISTING LIGHT CONTROL EXISTS FOR THIS AREA, OR ADJACENT TO THIS AREA, PROVIDE NEW AREA CONTROL CIRCUIT.
8	E.G. TO PROVIDE JUNCTION BOX AND EXTEND EMERGENCY "UNSWITCHED" CIRCUIT TO NEW LOCATION SHOWN. INSTALL AND MAKE FINAL CONNECTIONS TO RELOCATED EMERGENCY EGRESS FIXTURE.
9	E.G. TO VERIFY ALL EGRESS/NITE LIGHT FIXTURES AND THE AREA(S) THEY SERVE, IN AS MUCH AS POSSIBLE RETAIN THE SAME COVERAGE AREA(S) IN THE NEW SPACES SHOWN. IN NEW AREA(S) CREATED BY THE REMODEL, ADD OR RELOCATE EGRESS FIXTURES TO PROVIDE ADEQUATE COVERAGE PER LOCAL GOVERNING CODES.
10	E.G. TO EXTEND WIRING TO RELOCATED SPEAKER, AS SHOWN.
11	E.G. TO NEW CEILING SPEAKER, MATCH EXISTING, TAP INTO EXISTING SPEAKER "ZONE" AND EXTEND TO LOCATION SHOWN. PROVIDE ALL WIRING AND DEVICES.

CONTRACTOR NOTE
 WRITTEN DIMENSIONS HOLD PREFERENCE OVER SCALED DIMENSIONS. DO NOT SCALE DRAWING. CONTRACTORS MUST VISIT JOB SITE TO VERIFY ALL EXISTING CONDITIONS AND DIMENSIONS BEFORE SUBMITTING BIDS. REPORT ANY DISCREPANCIES OF ANY CONDITIONS WHICH MAY INTERFERE WITH THE PROPER EXECUTION OF WORK, TO TENANT REPRESENTATIVE. REPORT DISCREPANCIES DURING BIDDING PROCESS AND BEFORE START OF CONSTRUCTION. EXTRAS WILL NOT BE ALLOWED FOR JOB OR CODE COMPLIANCE CONDITIONS AFTER COMMENCEMENT OF CONSTRUCTION.

REFLECTED CEILING PLAN GENERAL NOTES

A. ALL SPEAKERS, DIFFUSERS, EMERGENCY UNIT BASE PLATES, RECEPTACLES, ACCESS PANELS, AND COVER PLATES IN LAY-IN CEILING TO BE PAINTED TO MATCH ADJACENT CEILING, SEE ELECTRICAL AND MECHANICAL DRAWINGS FOR LOCATIONS.

B. EXIT SIGNS MUST BE INTERNALLY ILLUMINATED.

C. CROSS REFERENCE TO BOTH SHEETS A101 AND E101 FOR LIGHTING FIXTURE INFO, SPECIFICATIONS & PLACEMENT. NOTIFY ARCHITECT OF ANY DISCREPANCIES.

D. SPRINKLER PLANS AND SPECS TO BE SUBMITTED BY SPRINKLER CONTRACTOR. SPRINKLER CONTRACTOR TO SUBMIT PLANS TO BUILDING DEPARTMENT AND OBTAIN PERMIT. REFER TO SPRINKLER DRAWINGS FOR SPRINKLER INFORMATION IN ALL AREAS.


E. ALL WIRING MUST BE IN RIGID CONDUIT.

F. DO NOT ABANDON ANY UTILITIES OR MATERIALS WITHIN SPACE, REMOVE BACK TO SOURCE.

G. SUPPORT WIRES FOR CEILING ITEMS MUST NOT BE CONNECTED TO ANY OF L.L. MECH, ELEC, PLUMBING OR FIRE PROTECTION PIPING OR EQUIPMENT.

H. FIRE ALARM SYSTEM IS LOCATED ON THE FIRST FLOOR. CONSULT WITH LANDLORD FOR FIRE ALARM SPECIFICS. PROVIDE NEW DEVICES AND "TIE-INTO" EXISTING SYSTEM. E.G. TO PROVIDE AND INSTALL ALL EQUIPMENT.



LIGHT FIXTURE SCHEDULE											LAMP SCHEDULE				
QTY	I.D.	SYMBOL	MANUFACTURER	CATALOG NO.	DESCRIPTION	REF NOTES	VOLTS	REC	SUR	PEN	WAL	LAMP/FIXT	WATTS/LAMP	FIXTURE WATTS	LAMP TYPE
1	A		LITHONIA LIGHTING	WC 2 25 120 GB10IS	3" FLUORESCENT WALL MOUNT W/ LENS	1	120		X		X	1	28	58	(2) F025/850/XP/ECO

1. PROVIDE LAMP WITH FIXTURE

1 ELECTRICAL CEILING PLAN
 SCALE: 1/8"=1'-0"

REGISTRATION SEAL

ARCVISION
 INCORPORATED
 ARCHITECTURE • ENGINEERING • STORE PLANNING
 SAINT LOUIS / DALLAS / LAS VEGAS / ORLANDO
 1950 CRAIG ROAD, SUITE 300 ST. LOUIS, MO 63146
 PH: (314) 415-2400 FAX: (314) 415-2300 www.arcv.com

STIFEL NICOLAUS
 500 CHESTERFIELD CENTER
 CHESTERFIELD, MO
 SUITE 240 + 250

REV	DATE	DESCRIPTION

PROJECT NO: 090748
 DRAWN BY: SH
 CHECKED BY: SH
 ISSUE DATE: 11/04/09

E101

ELECTRICAL CEILING PLAN